

Certificate of Compliance

Certificate Number 20090514 – MH8290A
Report Reference MH8290, 1993 October 05
Issue Date 2009 May 14

Page 1 of 1



Issued to: **TUTHILL TRANSFER SYSTEMS**
8825 AVIATION DR
FT WAYNE, IN 46809 USA

This is to certify that representative samples of

Flammable Liquid Meters


Model Descriptions: Flammable-liquid meters - Models 806B, 806C, 807B, 807C, 886, and 887; Series 900.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **The basic standards used to investigate products in this category are ANSI/UL 25, "Meters for Flammable and Combustible Liquids and LP-Gas" and CAN/CSA C22.2 No. B346-M1980, ""Power-Operated Dispensing Devices for Flammable Liquids."**

Additional Information: **None**

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Jim Larin*
Jim Larin, Customer Service Specialist
Underwriters Laboratories Inc.

Reviewed by: *Robert Zeman*
Robert Zeman, Section Manager I
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL
For questions in The United States of America you may call 1-877-UL-HELPS.